




Nr.	Designation	Ref./DN	QTY	✓
1	ADCAIHERM-TDG Deaerator tower		1	
2	Storage vessel		1	
3	ADCAIROL make-up water		1	
3.1	Condensate return		1	
4	Vent valve with regulating cone		1	
5	.		1	
6	ADCAIROL storage water temp. control		1	
7	ADCA SI steam injection system		1	
8	ADCA S25 humidity separator with trap		1	
9	ADCA FLT steam trap overflow		1	
9.1	Alternative mot. valve overflow		1	
10	Safety valve		1	
11	ADCA RD40 check v. vacuum breaker		1	
12	ADCA VB21 Vacuum breaker		1	
13	Level control		1	
14	Level indicator		1	
15	Vortex breaker		1	
16	Service supply		1	
17	Dosing chemical supply		1	
18	Rtd probe		1	
19	Temperature indicator		1	
20	ADCA MAN 100 pressure indicator		1	
21	ADCA DW sight glass		1	
22	Drain		1	

(TO BEX, see ADBEX.01.2839)

VALSTEAM		Proc. 0.490
ADCA ENGINEERING SA		
Proj. 07/09/24 F. Soares		Des.N.º ADIDCV.04.2843
Des. 07/09/24 Paulo S.		Rev. 00 Em. 00/00/00
Verif.		
Descrição:		
THERMAL DEAERATOR TDG-V		
Without steam dome injection		
Typical installation		
Tolerâncias n.º especificadas		
Dimensões	Desvios	
> 0 a 5	±0,2	
> 5 a 30	±0,3	
> 30 a 100	±0,5	
> 100	±0,8	
Ângulos +/- 30°		
Outros / Notas 03		